

Ca. 1000 people gathered in the main hall of the city hall to hear the speech. The speaker was the Mayor of the city, who said that the city was proud to have a person of the speaker's caliber. He also said that the city was proud to have a person of the speaker's caliber.

S P E Z I F I K A T I O N

POS.

Spiralwärmeaustauscher Typ 3V für Löser/Nutschen

107.13

301.13

402.13

408.13

332.13

333.13

335.13

Spiralkörper:

aus nichtrostendem Stahl AISI 316L

Breite: 250 mm

Durchmesser: 420 mm

Kanäle: 6/8 mm

Design Code

ohne

Fläche:

9,08 m²

506.13

Anschlüsse:

aus nichtrostendem Stahl AISI 316 L

Flanschen nach DIN 2674, ND16

aus Baustahl

Design code:

ohne

Deckel:

Baustahl, Innenseite mit nichtrostendem Stahlblech AISI 316 L plattiert, mit Hakenbolzen M20 am Spiralkörper befestigt.

Dichtungen:

Cylon Fawn

Betriebsdruck:

prim: -- bar sek: -- bar

Auslegedruck:

prim: 6 bar sek: 6 bar

Prüfdruck:

prim: 7,8 bar sek: 7,8 bar

Auslegetemperatur:

200 °C

Leergewicht:

330 kg

Inhalt:

prim: 38 l sek: 34 l

Abmessungen:

gemäss beil. Massblatt DS 11101
(Änderungen vorbehalten)

Anstrich:

ALFA-LAVAL Standard

Betriebsbedingungen

Leistung:

283 kW

Medium 1: produktseitig LM-G 1728 kg/h (2.41 ATA)

Temperatur EIN/AUS: 80 °C

Kondensataustrittstemp.: 37,1 °C

Druckabfall: 2,9 m bar

Medium 2: energieseitig

Wasser 12263 kg/h

Temperatur EIN/AUS:

22 °C / 42 °C

Druckabfall:

0,22 bar