



DESCRIPTION	
B12	DOSAGE PUMPS HOUSING
B125 (1,2,3)	DOSAGE PUMPS WATER DISCHARGE Ø30 mm
B12E	DOSAGE PUMPS CABINET
B140E	POWER CONTROL PANEL
B140P	ELECTRICAL CONTROL CABINET
B140W	1" ELECTRICAL WELLMAN'S CABINET (SS1)
B150	ELECTRICAL CONNECTION POINT (MAX. POWER 50 Kw 400Volt 3 phases + neutral + earth on electrical cabinet B14) TANK
B160	COMPRESSED AIR INLET
B46	O.I.T. PAN
B47	O.I.T. TANK
B910	UPS 1.500VA 230VOLT
B127	UNIDIRECTIONAL VALVE VENTEX ES-E DN100 A/V/S4
B129	SUPPLIED COLD WATER (7,2 m³/h; 120 lt/min; 3,5 Bar)
B131	DRAINED WATER (6,0 m³/h; 100 lt/min)
B133	CONDENSATE (50 Kg/h; 1,5 Bar)
B134	ETHANOL (10 m³/h)
B135	ISOPROPANOL (10m³/h)
B136	NITROGEN (1Nm³/min; 1000 Nit/min; 4 Bar)
B137	STEAM 50kg/h 1,5 bar
B138	COMPRESSED AIR HEATER
B138P	PNEUMATICAL CABINET AIR COMPRESSED HEATER
B140	COMPRESSED AIR INLET-PALL FILTER (pointCIP) MAX. COMPRESSED AIR CONSUMPTION 3000 l/min AT 3.5 bar
B170	2" ELECTRICAL WELLMAN'S CABINET (KK1)
B180	PNEUMATIC WELLMAN'S CABINET (Vx1)
B100	TANK 1700 Lt

DESCRIPTION	
C9	SOUND-PROOF BOX FOR OUTLET AIR FAN (OPTIONAL)

ATTENTION: Keep always signal cables away and separate from power cables

Limiti di fornitura:
Battery limits:

CLIENTE/CUSTOMER

IMA

CUSTOMER BOEHRINGER INGELHEIM		CHECKED / APPROVED <i>[Signature]</i>	DATE 07/08/08
COUNTRY GERMANIA	LINE TANK 1700 Lt.	DRAWN UP 37-RIZZI	SHEET 1/1
REPLACING GZ100EGZ1159R07-T	REPLACED BY	SERIAL No. GZ1159	DRAWING No. GZ100EGZ1159R08-T
SCALE 1:25		SCALE 1:25	