## INITIAL INSPECTION CERTIFICATE PORTABLE TANK (§6.7) TANK CONTAINER (§6.8)



Report n°: AVS /4.13.15.5275/04/26 Rev. 1 TWSU 752051 - 7 BVCT: 13.7.0275/A BIC: Tare: 3420 kg Max. gross weight: 36000 kg Payload: 32580 kg Owner: TWS Tankcontainer Leasing GmbH & Co. KG - Dorfstrasse 13 -Operator: -D - 19246 Camin Portable Tank instruction: T1 ADR/RID tank code: L4AN Special provisions: None Model: TCIS20-25/T1 Serial n°: 116910 Type code: 2NKD Type : UN Portable Tank / Tank Container **Dimensions** (mm): 6058 x 2550 x 2895 mm <u>APPROVALS</u> 25000 MAWP ADR/RID/IMDG §6.7 MAWP ADR/RID §6.8 ADR/RID/IMDG §6.7: 1,76 bar B63200 **UIC 592** ADR/RID §6.8: B53343 bar Test pressure ADR/RID/IMDG §6.7 2,64 bar B-BV-63200 ACEP. Test pressure ADR/RID §6.8 bar D-HH-15 SUBSTANCES SUITABLE FOR TRANSPORT: In accordance with the requirements of the applicable regulations and the construction of the tank and its equipment. (Substances not compatible with the tank and/or its accessories are excluded for transport)

MANUFACTURER: VAN HOOL NV - Belgium Manufacturer's stamp STATEMENT OF THE MANUFACTURER: I, the undersigned, certify that the above mentioned VAN HOOL NV - BELGIUM tank container (tank n°116910) has been manufactured in the same way as the basic prototype container certified by BUREAU VERITAS under n° BVCT 987.0270/G, BVCT 13.7.0013/A and Technical Department Tel.: 03/420.20.20 BVCT 13.7.0275/A. CHARACTERISTICS INSPECTIONS GENERAL DRAWING N° 116885-006 This tank container has been manufactured under BUREAU VERITAS survey, in accordance with the following prescriptions: **DESIGN** Design code EN 14025 - Rules of : BUREAU VERITAS - T02/14 -40 / 150 °C Design temperature - Code FN 14025 Design pressure IMDG Code Amendment 36-12 bar External design pressure 0,21 **ADR/RID 2013** bar ADR/RID calc. pressure bar The inspections performed are subject to reports : **MATERIALS** : L/130.910 Frame St.52 Tank Shell SANS 50028-7 - 1.4402 **Tank Heads** SANS 50028-7 - 1.4402 INSPECTIONS PERFORMED Verification of the conformity with the prototype. TANK External diameter 2390 mm Number of compartments : Visual internal and external inspection of the tank. Number of baffles None Design thickness Visual inspection of the frame. Shell Nominal 3.00 Minimum : 3,00 Minimum : 4,33 mm mm Heads Hydrostatic pressure test of the tank: - At a pressure of : 4 bar-- Performed on : 28/03/2014 Equivalent thickness mild steel ADR-RID / IMDG Shell 6/4 6/4 mm mm External tank area 48.91 m<sup>2</sup> Pneumatic tightness test of the tank equipment: - At a pressure of : 1 bar-- Performed on : 25/04/2014 <u>EQUIPMENT</u> Heater type Heater work pressure Steam Satisfactory operation of the service equipment. bar Heater test pressure 4,5 Top Bottom Outlet No Closures Verification of the markings :-:2 Yes Closures Review of radiographs: SAFETY DEVICES 10% of circumferential and longitudinal shell welds 10% of welds in head section 1 Setting Fort Vale 013/148128SL : 3.3/-0.21 bar Relief valve Relief valve type Relief valve serial no. 1488757 Setting Rupture disc bar Mounting REMARKS Installed vent capacity 14594 m<sup>3</sup>/hr Minimum vent capacity 11366 m³/hr Date of next statutory examination: 09/2016 1.4402 = modified 1.4404 COATING / INSULATION Max. operating temperature: 100°C Internal None External : PIR TESTS Stacking at R: 36000 72000 Transverse Racking test SRS obtained at R = 36000 kg Impact test at MARKING Drawing. N° 116885-I FT STAMPING ANTWERP Issued at : On date of: 08/04/2015 K. DE GRUYTER Inspected by : 3/2014 P on identification plate Region-Office: ANTWERP